## LPCB®

www.redbooklive.com



is authorised to use the LPCB mark in association with the product(s) listed in this certificate and appendix having complied with the requirements of the standard(s) detailed below:

## Product(s)

Cable Types as listed below: RAMFIRECRO-F3 FIRE COMET

## Standard(s) (see Appendix for details)

EN 50200:2015 (Class PH30) EN 61034-2:2005+A1:2013 EN 60754-1:2014

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

KAUGUL.	Karen Coull	27 April 2018	15 February 2018
Signed for BRE Global Ltd.	Certification Scheme Manager	Date of Issue	Date of First issue
LPCB B C C C C C C C C C C C C C	This certificate and appendix remain the subject to terms and conditions (for de To check the validity of this certificate <u>www.redbooklive.com/check</u> , scan the BRE Global Ltd, Garston, Watford, WD T: +44 (0)333 321 8811 E: <u>enquiries@</u> LPCB <sup>®</sup> is a registered trademark of the	etails visit <u>www.redbooklive.com/term</u> and appendix please visit e QR tag or contact us. 225 9XX 2breglobal.com	

12.0 0

80018

# **LPCB**<sup>®</sup>

## Appendix to Certificate No: 568i RAMCRO S.p.A.

## Issue: 02

Product name					
RAMFIRECRO-F3 FIRE COMET					
Nominal csa of conductor (mm <sup>2</sup> )	Core Construction	EN 50200	EN 61034-2	EN 60754-1	
1.0	2	PH 30	>60%	<0.5% HCI	
1.5	2	PH 30	>60%	<0.5% HCI	
2.5	2	PH 30	>60%	<0.5% HCI	

### Uo/U 100/100V

#### Notes:

1. Flexible stranded conductors only.

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

Killouch.	Karen Coull	27 April 2018	15 February 2018
Signed for BRE Global Ltd.	Certification Scheme Manager	Date of Issue	Date of First issue
LPCB A A A A A A A A A A A A A		e QR tag or contact us. D25 9XX <u>@breglobal.com</u>	bre