

Certificate of Product Approval

Certificate Number: 1395c

Issue: 03

Zhongshan Guta Fire Equipment Technology Co Ltd

4/F 10# Xingye Road,
Huoju District,
Zhongshan City,
Guangdong,
528400
China



is certified by BRE Global Ltd. and is authorised to use the LPCB mark in association with the product(s) listed in this certificate and appendix having complied with the requirement(s) of the standards as detailed below:

Products

Control and Indicating Equipment

AW-CFP2166-4
AW-CFP2166-8
AW-CFP2166-12
AW-CFP2166-16
AW-CFP2166-20
AW-CFP2166-24
AW-CFP2166-28
AW-CFP2166-32

Standards

EN 54-2:1997 + A1:2006

EN 54-4:1997 + A1:2002 + A2:2006

(refer to Appendix for details)

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

P. Halligan

Signed for BRE Global Ltd

P Halligan

Verifier

11 June 2021

Date of Issue

06 March 2019

Date of First Issue



This certificate and appendix remains the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

BRE Global Ltd, Watford, WD25 9XX

T: +44 (0)333 321 8811 F: +44 (0)1923 664603 E: enquiries@breglobal.com

LPCB is a Registered Trademark of the Building Research Establishment Ltd.



bre

Appendix to Certificate No: 1395c

Issue: 03

Zhongshan Guta Fire Equipment Technology Co Ltd

Certified Product	Description	LPCB Ref.No.										
AW-CFP2166-4	<p>4 Zone Conventional Control and Indicating Equipment</p> <p>Incorporating the following units:</p> <table><tr><td>Asenware Main Board</td><td>Main Board</td></tr><tr><td>Asenware Interface Board</td><td>Interface Board</td></tr><tr><td>Asenware PSE</td><td>Power and Charger Board</td></tr><tr><td>Asenware Zonal Board</td><td>1 x 4 Zone Board</td></tr><tr><td>Asenware EMI</td><td>EMI Board</td></tr></table> <p>Certified with the following options with requirements from EN54-2: 1997 + A1: 2006:</p> <p>7.8 Output to fire alarm devices (option with requirements)</p> <p>7.9.1 Output to fire alarm routing equipment (option with requirements)</p> <p>7.10.1 Output type A (option with requirement)</p> <p>7.10.2 Output type B (option with requirement)</p> <p>8.9 Output to fault warning routing equipment (option with requirements)</p> <p>Note:</p> <p>1. This product approval does not constitute compliance with the fire detection and alarm systems requirements of EN 54-13.</p>	Asenware Main Board	Main Board	Asenware Interface Board	Interface Board	Asenware PSE	Power and Charger Board	Asenware Zonal Board	1 x 4 Zone Board	Asenware EMI	EMI Board	1395c/01
Asenware Main Board	Main Board											
Asenware Interface Board	Interface Board											
Asenware PSE	Power and Charger Board											
Asenware Zonal Board	1 x 4 Zone Board											
Asenware EMI	EMI Board											
AW-CFP2166-8	<p>8 Zone Conventional Control and Indicating Equipment</p> <p>Incorporating the following units:</p> <table><tr><td>Asenware Main Board</td><td>Main Board</td></tr><tr><td>Asenware Interface Board</td><td>Interface Board</td></tr></table>	Asenware Main Board	Main Board	Asenware Interface Board	Interface Board	1395c/02						
Asenware Main Board	Main Board											
Asenware Interface Board	Interface Board											

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

P Halligan
Signed for BRE Global Ltd

P Halligan
Verifier

11 June 2021
Date of Issue

06 March 2019
Date of First Issue



This certificate and appendix remains the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

BRE Global Ltd, Watford, WD25 9XX
T: +44 (0)333 321 8811 F: +44 (0)1923 664603 E: enquiries@breglobal.com

LPCB is a Registered Trademark of the Building Research Establishment Ltd.



bre

Appendix to Certificate No: 1395c

Issue: 03

Zhongshan Guta Fire Equipment Technology Co Ltd

Certified Product	Description	LPCB Ref.No.
	<p>Asenware PSE Power and Charger Board</p> <p>Asenware Zonal Board 2 x 4 Zone Boards</p> <p>Asenware EMI EMI Board</p> <p>Certified with the following options with requirements from EN54-2: 1997 + A1: 2006:</p> <p>7.8 Output to fire alarm devices (option with requirements)</p> <p>7.9.1 Output to fire alarm routing equipment (option with requirements)</p> <p>7.10.1 Output type A (option with requirement)</p> <p>7.10.2 Output type B (option with requirement)</p> <p>8.9 Output to fault warning routing equipment (option with requirements)</p> <p>Note:</p> <p>1. This product approval does not constitute compliance with the fire detection and alarm systems requirements of EN 54-13.</p>	
AW-CFP2166-12	<p>12 Zone Conventional Control and Indicating Equipment</p> <p>Incorporating the following units:</p> <p>Asenware Main Board Main Board</p> <p>Asenware Interface Board Interface Board</p> <p>Asenware PSE Power and Charger Board</p> <p>Asenware Zonal Boards 3 x 4 Zone Boards</p> <p>Asenware EMI EMI Board</p>	1395c/03

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

P Halligan
Signed for BRE Global Ltd

P Halligan
Verifier

11 June 2021
Date of Issue

06 March 2019
Date of First Issue



This certificate and appendix remains the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

BRE Global Ltd, Watford, WD25 9XX
T: +44 (0)333 321 8811 F: +44 (0)1923 664603 E: enquiries@breglobal.com

LPCB is a Registered Trademark of the Building Research Establishment Ltd.



bre

Appendix to Certificate No: 1395c

Issue: 03

Zhongshan Guta Fire Equipment Technology Co Ltd

Certified Product	Description	LPCB Ref.No.										
	<p>Certified with the following options with requirements from EN54-2: 1997 + A1: 2006:</p> <p>7.8 Output to fire alarm devices (option with requirements)</p> <p>7.9.1 Output to fire alarm routing equipment (option with requirements)</p> <p>7.10.1 Output type A (option with requirement)</p> <p>7.10.2 Output type B (option with requirement)</p> <p>8.9 Output to fault warning routing equipment (option with requirements)</p> <p>Note:</p> <p>1. This product approval does not constitute compliance with the fire detection and alarm systems requirements of EN 54-13.</p>											
AW-CFP2166-16	<p>16 Zone Conventional Control and Indicating Equipment</p> <p>Incorporating the following units:</p> <table><tr><td>Asenware Main Board</td><td>Main Board</td></tr><tr><td>Asenware Interface Board</td><td>Interface Board</td></tr><tr><td>Asenware PSE</td><td>Power and Charger Board</td></tr><tr><td>Asenware Zonal Boards</td><td>4 x 4 Zone Boards</td></tr><tr><td>Asenware EMI</td><td>EMI Board</td></tr></table> <p>Certified with the following options with requirements from EN54-2: 1997 + A1: 2006:</p> <p>7.8 Output to fire alarm devices (option with requirements)</p> <p>7.9.1 Output to fire alarm routing equipment (option with requirements)</p> <p>7.10.1 Output type A (option with requirement)</p>	Asenware Main Board	Main Board	Asenware Interface Board	Interface Board	Asenware PSE	Power and Charger Board	Asenware Zonal Boards	4 x 4 Zone Boards	Asenware EMI	EMI Board	1395c/04
Asenware Main Board	Main Board											
Asenware Interface Board	Interface Board											
Asenware PSE	Power and Charger Board											
Asenware Zonal Boards	4 x 4 Zone Boards											
Asenware EMI	EMI Board											

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

P Halligan
Signed for BRE Global Ltd

P Halligan
Verifier

11 June 2021
Date of Issue

06 March 2019
Date of First Issue



This certificate and appendix remains the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

BRE Global Ltd, Watford, WD25 9XX
T: +44 (0)333 321 8811 F: +44 (0)1923 664603 E: enquiries@breglobal.com

LPCB is a Registered Trademark of the Building Research Establishment Ltd.



bre

Appendix to Certificate No: 1395c

Issue: 03

Zhongshan Guta Fire Equipment Technology Co Ltd

Certified Product	Description	LPCB Ref.No.										
	<p>7.10.2 Output type B (option with requirement)</p> <p>8.9 Output to fault warning routing equipment (option with requirements)</p> <p>Note:</p> <p>1. This product approval does not constitute compliance with the fire detection and alarm systems requirements of EN 54-13.</p>											
AW- CFP2166-20	<p>20 Zone Conventional Control and Indicating Equipment</p> <p>Incorporating the following units:</p> <table><tr><td>Asenware Main Board</td><td>Main Board</td></tr><tr><td>Asenware Interface Board</td><td>Interface Board</td></tr><tr><td>Asenware PSE</td><td>Power and Charger Board</td></tr><tr><td>Asenware Zonal Boards</td><td>5 x 4 Zonal Boards</td></tr><tr><td>Asenware EMI</td><td>EMI Board</td></tr></table> <p>Certified with the following options with requirements from EN54-2: 1997 + A1: 2006:</p> <p>7.8 Output to fire alarm devices (option with requirements)</p> <p>7.9.1 Output to fire alarm routing equipment (option with requirements)</p> <p>7.10.1 Output type A (option with requirement)</p> <p>7.10.2 Output type B (option with requirement)</p> <p>8.9 Output to fault warning routing equipment (option with requirements)</p> <p>Note:</p> <p>1. This product approval does not constitute compliance with the fire detection and alarm systems requirements of EN 54-13.</p>	Asenware Main Board	Main Board	Asenware Interface Board	Interface Board	Asenware PSE	Power and Charger Board	Asenware Zonal Boards	5 x 4 Zonal Boards	Asenware EMI	EMI Board	1395c/05
Asenware Main Board	Main Board											
Asenware Interface Board	Interface Board											
Asenware PSE	Power and Charger Board											
Asenware Zonal Boards	5 x 4 Zonal Boards											
Asenware EMI	EMI Board											

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

P. Halligan
Signed for BRE Global Ltd

P Halligan
Verifier

11 June 2021
Date of Issue

06 March 2019
Date of First Issue



This certificate and appendix remains the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

BRE Global Ltd, Watford, WD25 9XX
T: +44 (0)333 321 8811 F: +44 (0)1923 664603 E: enquiries@breglobal.com

LPCB is a Registered Trademark of the Building Research Establishment Ltd.



bre

Appendix to Certificate No: 1395c

Issue: 03

Zhongshan Guta Fire Equipment Technology Co Ltd

Certified Product	Description	LPCB Ref.No.										
AW-CFP2166-24	<p>24 Zone Conventional Control and Indicating Equipment</p> <p>Incorporating the following units:</p> <table><tr><td>Asenware Main Board</td><td>Main Board</td></tr><tr><td>Asenware Interface Board</td><td>Interface Board</td></tr><tr><td>Asenware PSE</td><td>Power and Charger Board</td></tr><tr><td>Asenware Zonal Boards</td><td>6 x 4 Zone Boards</td></tr><tr><td>Asenware EMI</td><td>EMI Board</td></tr></table> <p>Certified with the following options with requirements from EN54-2: 1997 + A1: 2006:</p> <p>7.8 Output to fire alarm devices (option with requirements)</p> <p>7.9.1 Output to fire alarm routing equipment (option with requirements)</p> <p>7.10.1 Output type A (option with requirement)</p> <p>7.10.2 Output type B (option with requirement)</p> <p>8.9 Output to fault warning routing equipment (option with requirements)</p> <p>Note:</p> <p>1. This product approval does not constitute compliance with the fire detection and alarm systems requirements of EN 54-13.</p>	Asenware Main Board	Main Board	Asenware Interface Board	Interface Board	Asenware PSE	Power and Charger Board	Asenware Zonal Boards	6 x 4 Zone Boards	Asenware EMI	EMI Board	1395c/06
Asenware Main Board	Main Board											
Asenware Interface Board	Interface Board											
Asenware PSE	Power and Charger Board											
Asenware Zonal Boards	6 x 4 Zone Boards											
Asenware EMI	EMI Board											
AW-CFP2166-28	<p>28 Zone Conventional Control and Indicating Equipment</p> <p>Incorporating the following units:</p> <table><tr><td>Asenware Main Board</td><td>Main Board</td></tr><tr><td>Asenware Interface Board</td><td>Interface Board</td></tr></table>	Asenware Main Board	Main Board	Asenware Interface Board	Interface Board	1395c/07						
Asenware Main Board	Main Board											
Asenware Interface Board	Interface Board											

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

P Halligan
Signed for BRE Global Ltd

P Halligan
Verifier

11 June 2021
Date of Issue

06 March 2019
Date of First Issue



This certificate and appendix remains the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

BRE Global Ltd, Watford, WD25 9XX
T: +44 (0)333 321 8811 F: +44 (0)1923 664603 E: enquiries@breglobal.com

LPCB is a Registered Trademark of the Building Research Establishment Ltd.



bre

Appendix to Certificate No: 1395c

Issue: 03

Zhongshan Guta Fire Equipment Technology Co Ltd

Certified Product	Description	LPCB Ref.No.
	<p>Asenware PSE Power and Charger Board</p> <p>Asenware Zonal Boards 7 x 4 Zone Boards</p> <p>Asenware EMI EMI Board</p> <p>Certified with the following options with requirements from EN54-2: 1997 + A1: 2006:</p> <p>7.8 Output to fire alarm devices (option with requirements)</p> <p>7.9.1 Output to fire alarm routing equipment (option with requirements)</p> <p>7.10.1 Output type A (option with requirement)</p> <p>7.10.2 Output type B (option with requirement)</p> <p>8.9 Output to fault warning routing equipment (option with requirements)</p> <p>Note:</p> <p>1. This product approval does not constitute compliance with the fire detection and alarm systems requirements of EN 54-13.</p>	
AW-CFP2166-32	<p>32 Zone Conventional Control and Indicating Equipment</p> <p>Incorporating the following units:</p> <p>Asenware Main Board Main Board</p> <p>Asenware Interface Board Interface Board</p> <p>Asenware PSE Power and Charger Board</p> <p>Asenware Zonal Boards 8 x 4 Zone Boards</p> <p>Asenware EMI EMI Board</p>	1395c/08

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

P Halligan
Signed for BRE Global Ltd

P Halligan
Verifier

11 June 2021
Date of Issue

06 March 2019
Date of First Issue



This certificate and appendix remains the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

BRE Global Ltd, Watford, WD25 9XX
T: +44 (0)333 321 8811 F: +44 (0)1923 664603 E: enquiries@breglobal.com

LPCB is a Registered Trademark of the Building Research Establishment Ltd.




bre

Appendix to Certificate No: 1395c

Issue: 03

Zhongshan Guta Fire Equipment Technology Co Ltd

Certified Product	Description	LPCB Ref.No.
	<p>Certified with the following options with requirements from EN54-2: 1997 + A1: 2006:</p> <p>7.8 Output to fire alarm devices (option with requirements)</p> <p>7.9.1 Output to fire alarm routing equipment (option with requirements)</p> <p>7.10.1 Output type A (option with requirement)</p> <p>7.10.2 Output type B (option with requirement)</p> <p>8.9 Output to fault warning routing equipment (option with requirements)</p> <p>Note:</p> <p>1. This product approval does not constitute compliance with the fire detection and alarm systems requirements of EN 54-13.</p>	



This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

	P Halligan	11 June 2021	06 March 2019
Signed for BRE Global Ltd	Verifier	Date of Issue	Date of First Issue



This certificate and appendix remains the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

BRE Global Ltd, Watford, WD25 9XX
T: +44 (0)333 321 8811 F: +44 (0)1923 664603 E: enquiries@breglobal.com

LPCB is a Registered Trademark of the Building Research Establishment Ltd.



Appendix to Certificate No: 1395c

Issue: 03

Zhongshan Guta Fire Equipment Technology Co Ltd

Alternative Model No./Label

LPCB Ref No.	Model No.	Alternative Model No./Label	Cross-listed company	Cross-Listed Co Cert./ Ref No.
1395c/02	AW-CFP2166-8	FF CF608	Finder Yangin Güvenlik Elektronik Sistemler A.Ş	1395c-(cl-1)



This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

	P Halligan	11 June 2021	06 March 2019
Signed for BRE Global Ltd	Verifier	Date of Issue	Date of First Issue



This certificate and appendix remains the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

BRE Global Ltd, Watford, WD25 9XX
T: +44 (0)333 321 8811 F: +44 (0)1923 664603 E: enquiries@breglobal.com

LPCB is a Registered Trademark of the Building Research Establishment Ltd.

