LGAI Technological Center, S.A. Campus de la UAB Apartado de Correos 18 E - 08193 Bellaterra (Barcelona) T+34 93 567 20 00 F+34 93 567 20 01 www.applus.com





# **CERTIFICATE**



Nr.

0370-CPR-1700

#### CERTIFICATE OF CONSTANCY OF PERFORMANCE

In compliance with Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product:

- FIRE DETECTION AND FIRE ALARM SYSTEMS, PART 5: HEAT DETECTORS, POINT DETECTORS
- FIRE DETECTION AND FIRE ALARM SYSTEMS. PART 7: SMOKE DETECTORS. POINT DETECTORS USING SCATTERED LIGHT, TRANSMITTED LIGHT OR IONIZATION

ADRESSABLE COMBINATION SMOKE AND HEAT DETECTOR. TRADEMARK ZITON ZP732-2P, TRADEMARK CHUBB ZP732-2S30 AND TRADEMARK EDWARDS EA32E-2

Produced by:

UTC FIRE & SECURITY B.V. KELVINSTRAAT, 7 6003 DH WEERT (NETHERLANDS)

And produced in the manufacturing plant:

GULF SECURITY TECHNOLOGY CO. LTD.
No. 80 CHANGJIANG EAST ROAD, QETDZ, QINHUANGDAO, HEBEI, CHINA 066004

This certificate attests that all provisions concerning the assessment and verification of constancy of performance and the performances described in Annex ZA of the standard

EN 54-5:2000, EN 54-5:2000/A1:2002; EN 54-7: 2000; EN 54-7:2000/A1:2002, EN 54-7:2000/A2:2006

under system 1 are applied and that the product fulfils all the prescribed requirements set out above.

This certificate was first issued on 28<sup>th</sup> March 2014 and will remain valid as long as the test methods and/or factory production control requirements included in the harmonised standard, used to assess the performance of the declared characteristics, do not change, and the product, and the manufacturing conditions in the plant are not modified significantly.

Bellaterra, 28th March 2014

Applus LGAI Technological Center, S.A.

Jordi Brufau Redondo General Manager Acplus Denter, S.A.

Xavier Ruiz Peña

Product Conformity B.U., Managing Director

This document is not valid without its technical annex, whose number coincides with the number of certificate.



LGAI Technological Center, S.A. Campus UAB s/n E - 08193 Bellaterra (Barcelona) T +34 93 567 20 00 F +34 93 567 20 01 www.appluslaboratories.com



Technical Annex Ed.1

28/03/2014

TECHNICAL ANNEX 0370-CPR-1700

### **CERTIFICATE OF CONSTANCY OF PERFORMANCE**

Annexes according to EN 54-5: 2000 and EN 54-5: 2000/A1: 2002

Essential characteristics	Clauses in this European Standard	Mandated level(s) or class(es)	
Classification	4.2	A1 - A2	
Position of heat sensitive elements	4.3	PASS	
Individual alarm indication	4.4	PASS	
Connection of ancillary devices	4.5	PASS	
Monitoring of detachable detectors	4.6	PASS	
Manufacturer's adjustments	4.7	PASS	
On-site adjustment of response behaviour	4.8	PASS	
Marking	4.9	PASS	
Data	4.10	PASS	
Additional requirements for software controlled detectors	4.11	PASS	
Directional dependence	5.2	PASS	
Static response temperature	5.3	NPD	
Response times from typical application temperature	5.4	PASS	
Response times from 25 °C	5.5	NPD	
Response times from high ambient temperature (dry heat operational)	5.6	NPD	
Variation in supply parameters	5.7	NPD	
Reproducibility	5.8	PASS	
Cold (operational)	5.9	NPD	
Dry heat (endurance)	5.10	NPD	
Damp heat, cyclic (operational)	5.11	NPD	
Damp heat, steady state (endurance)	5.12	NPD	
Sulfur dioxide (SO2) corrosion (endurance)	5.13	PASS	
Shock (operational)	5.14	NPD	
Impact (operational)	5.15	NPD	
Vibration, sinusoidal (operational)	5.16	NPD	

PASS; NPD = No Performance Determined, NA = Not Apply



LGAI Technological Center, S.A. Campus UAB s/n E - 08193 Bellaterra (Barcelona) T +34 93 567 20 00 F +34 93 567 20 01 www.appluslaboratories.com



Technical Annex Ed.1

28/03/2014

**TECHNICAL ANNEX** 

0370-CPR-1700

## CERTIFICATE OF CONSTANCY OF PERFORMANCE

Annexes according to EN 54-5: 2000 and EN 54-5: 2000/A1: 2002

Essential characteristics	Clauses in this European Standard	Mandated level(s) or class(es)
Vibration, sinusoidal (endurance)	5.17	NPD
Electromagnetic compatibility (EMC), immunity tests (operational)	5.18	NPD
Test for suffix S detectors	6.1	NA
Test for suffix R detectors	6.2	NA

Standard mounting base:
ZP7-SB1 (Ziton)
ASBE-2 (Edwards)

PASS; NPD = No Performance Determined, NA = Not Apply



LGAI Technological Center, S.A. Campus UAB s/n E - 08193 Bellaterra (Barcelona) T +34 93 567 20 00 F +34 93 567 20 01 www.appluslaboratories.com



Technical Annex Ed.1

28/03/2014

**TECHNICAL ANNEX** 

0370-CPR-1700

## **CERTIFICATE OF CONSTANCY OF PERFORMANCE**

Annexes according to EN 54-7:2000, EN 54-7:2000/A1:2002 and EN 54-7:2000/A2:2006

Essential characteristics	Clauses in this European Standard	Mandated level(s) or class(es)
Individual alarm indication	4.2.	PASS
Connection of ancillary devices	4.3.	PASS
Monitoring of detachable detectors	4.4.	PASS
Manufacturer's adjustments	4.5.	PASS
On-site adjustment of response behaviour	4.6.	PASS
Protection against the ingress of foreign bodies	4.7.	PASS
Response to slowly developing fires	4.8.	PASS
Marking	4.9	PASS
Data	4.10.	PASS
Additional requirements for software controlled detectors	4.11.	NA
Repeatability	5.2.	PASS
Reproducibility	5.4.	PASS
Variation in supply parameters	5.5.	NPD
Air movement	5.6.	PASS
Dazzling	5.7.	PASS
Dry heat (operational)	5.8.	NPD
Cold (operational)	5.9.	NPD
Damp heat, steady state (operational)	5.10.	PASS
Damp heat, steady state (endurance)	5.11.	NPD
Sulfur dioxide (SO2) corrosion (endurance)	5.12.	PASS
Shock (operational)	5.13.	NPD
Impact (operational)	5.14.	PASS
Vibration, sinusoidal (operational)	5.15.	NPD
Vibration, sinusoidal (endurance)	5.16.	NPD
Electromagnetic compatibility (EMC), immunity tests (operational)	5.17.	NPD
Fire sensitivity	5.18.	PASS

PASS; NPD = No Performance Determined, NA = Not Apply

